Corporate Office
17522 Bothell Way Northeast
Bothell, Washington 98011
425.415.0551
www.riley-group.com

		Project No:	2019-134
		Report No:	135
		RGI rep:	Collin McCracken
		Date:	4/9/2021 Friday
Permit No:	SW18-00009	**Page No.**	1 of 1
Project:	Mallard Pointe	**Subject:**	Subgrade Observations Lot 22
Location:	Southeast 43rd Way and East Lake Sammamish Parkway Southeast, Issaquah	**Contractor:**	
Client Name:	Steve Burnstead Construction LLC	**Superintendent**	
& Address:	11980 Northeast 24th Street, Suite 200	**Visitors:**	
	Bellevue, WA 98005	**Weather:**	Sunny

OBSERVATIONS:
As requested, a Riley Group representative visited the site today to observe and evaluate the following:

Contractor has excavated to subgrade on lot 22. Subgrade was tested with a ½" steel tipped T-probe, and yielded less than ¼", indicating dense conditions suitable for the required bearing pressures.

RGI Rep sign: *Collin McCracken* Copies To:

Reviewed by *Kristina Weller*