Earth Solutions NW LLC
1805 - 136th Place N.E., Suite 201,
Bellevue, WA 98005
Phone (425) 449-4704 FAX (425) 449-4711

DAILY FIELD REPORT

Field Rep.	Project No.	Page of	Report No.
AJL	2453.20		02132022
Time On Site	**Time Off Site**	**Date**	**Day of Week**
1245	1:15	2/18/22	Friday
Travel Time		**Weather**	
1.5		45° Sunny	

Project Name	Job Location	Client / Owner
Westridge SF North (Vertical)	NE Discovery Dr & 9th Ave NE, Issaquah	Polygon - WL [illegible] Inc
General Contractor	**General Contractor's Superintendent**	**Received Onsite By**
Grading Contractor	**Grading Foreman**	**Checked By**

Are approved Plans/Permits onsite ☐ YES ☐ NO Project No. Permit No.

Lots 51 & 52 Footing Subgrade

ESNW Rep observed that the contractor had brought the lots to footing grade. ESNW probed the prepared footing subgrades using a 1/2" diameter steel T-probe. ESNW rep observed dense soil conditions in the probed areas. These observed conditions are considered suitable for support of the proposed SFR structures.

CONTINUED ON NEXT PAGE ☐